



SHEATHING OVER  
16GA. (1.5mm) (MIN.)  
STEEL STUD FRAMING  
(BY OTHERS)  
SPACED 16" (400mm) O.C. MAX.

FACTORY ATTACHED  
INTERLOCKING  
CHANNEL

FIELD ATTACH JOINT  
CHANNEL MATE THRU  
SHEATHING AND INTO  
EACH STUD W/ #10 (5mm)  
TEK SCREWS AS REQ'D.

USE BUILDEX "MAXISEAL"  
W/ NEOPRENE WASHER  
OR APPROVED EQUAL

AT CONC./CMU WALLS  
USE COATED TAP-CONS  
W/ NEOPRENE WASHER

SEALANT AND  
BACKER ROD  
(BY OTHERS - TYP.)

FACTORY ATTACHED  
JOINT CHANNEL

StoneLite® PANEL

VAPOR  
BARRIER  
SHEET  
(INSTALLED  
BY OTHERS)

WINDLOAD AND  
BEARING  
APPLICATION

WINDLOAD  
APPLICATION

1 7/8" (48mm)  
MIN. SHIM AS  
REQ'D.

DR-040(10Feb25)

**COLDSPRING®**  
17482 GRANITE WEST ROAD, COLD SPRING, MN 56320  
PHONE 320.685.3621 | WWW.COLDSPRINGUSA.COM

<b>DESCRIPTION:</b> NARROW INTERLOCKING JOINT CHANNEL		<b>DATE:</b> 3/12/2025
		<b>DRAWN BY:</b> JW
<b>SHEET #:</b> SP-4	<b>SCALE:</b> NOT TO SCALE	